

STATEMENT OF COMPLIANCE

Statement No.:
SC-DNVGL-SE-0190-05500-2

Issued
2021-04-16

Issued for:

Site Conditions Assessment

of

Wind Farm Zone Hollandse Kust (west)

Comprising:

Wind Turbines, Substation and Power Cables

Specified in Annex 1

Issued to:

Netherlands Enterprise Agency

Croeselaan 15
3521 BJ Utrecht
The Netherlands

According to:

DNVGL-SE-0190:2020-09

Project certification of wind power plants

Based on the documents:

CR-SC-DNVGL-SE-0190-05500-2

Certification Report, dated 2021-04-16

Changes of the site conditions are to be approved by DNV GL.

Hamburg, 2021-04-16

For DNV GL Renewables Certification

i.V. Fabio Pollicino
Service Line Leader Project Certification



By DAkkS according DIN EN IEC/ISO 17065
accredited Certification Body for products. The
accreditation is valid for the fields of certification
listed in the certificate.

Hellerup, 2021-04-16

For DNV GL Renewables Certification

Helena Hunt
Project Manager

STATEMENT OF COMPLIANCE – ANNEX 1

Statement No.: SC-DNVGL-SE-0190-05500-2

Page 2 of 3

Wind farm zone and coordinates

Coordinate system and datum

UTM Zone 31N
EPSG 25831
See table below

Coordinates for the polygon corner positions

Position no.	Easting	Northing
WFZ_01	535,872.2	5,814,654.0
WFZ_02	537,022.3	5,822,012.5
WFZ_03	534,999.3	5,822,170.2
WFZ_04	537,570.7	5,825,520.7
WFZ_05	537,761.1	5,826,738.8
WFZ_06	560,375.0	5,853,830.4
WFZ_07	556,100.8	5,831,438.1
WFZ_08	556,364.1	5,831,312.2
WFZ_09	549,503.4	5,823,303.3
WFZ_10	548,730.0	5,822,551.6
WFZ_11	549,065.8	5,821,741.1
WFZ_12	549,721.8	5,820,157.5
WFZ_13	547,496.6	5,820,125.9
WFZ_14	536,741.8	5,815,063.4

STATEMENT OF COMPLIANCE – ANNEX 1

Statement No.: SC-DNVGL-SE-0190-05500-2

Page 3 of 3

Wind conditions – general

Air density at 100 m

Approx. 1.22 kg/m³
(temperature and pressure dependent)

Minimum - Maximum air temperature

-9.7°C to 29.9°C
(40 year)

Air humidity

81.5% (average)

Average inclined flow

0°

Wind conditions – normal

Annual average wind speed (at 100m)

9.72 m/s

Weibull A-parameter (at 100 m)

11.11 m/s

Weibull k-parameter (at 100 m)

2.283

Wind conditions – extreme

Wind speed 50 year recurrence period, 10 min. (at 100 m)

41.4 m/s
(max. within the area)

Wind speed 1 year recurrence period, 10 min. (at 100 m)

33.4 m/s
(max. within the area)

Marine conditions

Highest astronomical tide (HAT)

1.7 m (LAT)

Lowest astronomical tide (LAT)

0.0 m (LAT)

Tidal variation HAT/LAT

1.7 m (LAT)

Significant wave height for 50 year recurrence period, $H_{s,50-yr}$

7.5 m

Significant wave height for 1 year recurrence period, $H_{s,1-yr}$

5.6 m

Peak wave period T_p for extreme for 50 year recurrence wave $H_{s,50-yr}$

12.2 s

Peak wave period T_p for extreme for 1 year recurrence wave $H_{s,1-yr}$

10.3 s

Extreme deterministic wave height for 50 year recurrence period, $H_{max,50-yr}$

14.1 m

Extreme deterministic wave height for 1 year recurrence period, $H_{max,1-yr}$

10.5 m

Interval of wave periods $T_{Hmax,50-yr}$, associated with $H_{max,50-yr}$

8.7 s -13.1 s

Interval of wave periods $T_{Hmax,1-yr}$, associated with $H_{max,1-yr}$

7.6 s – 11.0 s

Extreme wave crest height for 50 year recurrence period

11.8 m (LAT)

Extreme wave crest height for 1 year recurrence period

8.6 m (LAT)

Extreme high water level with recurrence period of 50 year

3.5 m (LAT)

Extreme high water level with recurrence period of 1 year

2.8 m (LAT)

Extreme low water level with recurrence period of 50 year

-0.9 m (LAT)

Extreme low water level with recurrence period of 1 year

-0.3 m (LAT)

Extreme current for 50 year recurrence period (depth averaged)

1.1 m/s

Extreme current for 1 year recurrence period (depth averaged)

1.0 m/s

Water level rise to year 2050 due to climate change

0.3 m

Water density

Approx. 1025 kg/m³

Minimum - Maximum sea temperature

1.7 to 19.2°C (monthly)

Soil Conditions

Layer

Mainly sand with
interbedded clay, silt and
silty sand layers

Friction angle, ϕ'

34-42°

Undrained shear strength, c_u

60-330 kPa